




**BUREAU
VERITAS**

Attestation of Conformity

Attestation No.: 1888AP0125N034003
Equipment: PV Grid Inverter
Brand Name: 
Test Model No.: Growatt 15000 TL3-S
Applicant: Shenzhen Growatt New Energy Technology Co., Ltd
1st East & 3rd Floor of Building A, Building B, Jiayu Industrial Park, #28,
Guanghui Road, Long Teng Community, Shiyuan Street, Baoan District,
Shenzhen, P.R.China
Report No.: PV180125N034, PV180125N034-1, PV180125N034-2, WT176001252

Use in accordance with regulations:

The inverters are tested for functional safety, grid protection, specified environmental influences and efficiency. For detailed information, please watch the corresponding test reports.

Applied rules and standards

IEC 60068-2-1:2007	Environmental testing – Part 2-1: Tests – Test A: Cold
IEC 60068-2-2:2007	Environmental testing – Part 2-2: Tests – Test B: Dry heat
IEC 60068-2-14:2009	Environmental testing – Part 2-14: Tests – Test N: Change of temperature
IEC 60068-2-30:2005	Environmental testing – Part 2-30: Tests – Test Db: Damp heat, cyclic (12h + 12h cycle)
IEC 61683:1999	Photovoltaic systems – Power conditioners – Procedure for measuring efficiency
IEC 61727:2004	Characteristics of the utility interface
IEC 62116:2014	Islanding prevention measures for utility-interconnected photovoltaic inverters

Name: Ted Wu
Senior Manager/ PV Inverter Team
Date: 2018-02-09

This document shall not be reproduced, except in full, without the written approval of Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch.
Information given in this document is related to the tested specimen of the described electrical sample.